



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2451</b>	24-Sep-2010	Number 7	Issue date 29-Apr-2016	30-Apr-2017

Page 1 of 2

## Product designation

**Firex, Model FXAW, 9.1 litre, water type portable fire extinguisher**  
(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Firex Distribution (Australia) Pty Ltd  
Unit 3, 11 Packard Avenue, CASTLE HILL, NSW, AUSTRALIA, 2154

## Registrant

Firex Distribution (Australia) Pty Ltd  
Unit 3, 11 Packard Avenue, CASTLE HILL, NSW, AUSTRALIA, 2154

### Producer

Firex Distribution (Australia) Pty Ltd  
Unit 3, 11 Packard Avenue, CASTLE HILL, NSW, AUSTRALIA, 2154

## Conformance criteria and evaluation

The Firex, Model FXAW, 9.1 litre, water type portable fire extinguisher has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian/New Zealand Standard AS/NZS 1841.2:2007, 'Portable fire extinguishers - Specific requirements for water type extinguishers'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. This equipment should only be used for the classification of fire for which it is rated. (Ref.: AS/NZS 1850).

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2451</b>	24-Sep-2010	Number 7	Issue date 29-Apr-2016	30-Apr-2017
				Page 2 of 2

## Technical specification

The following details are a representative extract of the technical specification for the Firex, Model FXAW, 9.1 litre, water type portable fire extinguisher and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

<b>Model:</b>	<b>FXAW</b>
<b>Agent capacity:</b>	9.0 litres
<b>Agent type:</b>	Water
<b>Rating:</b>	3A
<b>Operating pressure:</b>	690 kPa
<b>Discharge time:</b>	65 seconds
<b>Physical characteristics</b>	
<b>Height:</b>	630 mm
<b>Diameter:</b>	180 mm
<b>Total mass:</b>	12.3 kg
<b>Construction</b>	
<b>Cylinder:</b>	Welded steel
<b>Valve:</b>	Brass, chrome plated
<b>Handles:</b>	Stainless steel
<b>Recognised body ref.:</b>	SAI Global Cert. num.: SMK1511
<b>Reference technical data sheet</b>	Firex catalogue, Vol 1 Rev1, page 9