

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	<b>Firex Distribution (Australia) Pty Ltd</b>	Client ID	<b>105665</b>
Company Other Name		Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS/NZS 1841.4-2007 : Portable fire extinguishers - Specific requirements for foam type extinguishers</b>		
Scheme	<b>Global-Mark Product Conformance Scheme</b>		
Certification Review Date	<b>25/06/2019</b>	Certification Expiry Date	<b>8/04/2024</b>
Certificate Issue Date	<b>25/06/2019</b>	Certificate Last Update Date	<b>25/06/2019</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**  
**Unit 5, 11 Packard Avenue Castle Hill NSW 2154 Australia**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**

Unique Certificate Code: **A854DE3209DA70EDCA2584120024A2AE**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®





**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**

*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FXAF	FXAF	Firex	9.0 L Foam type fire extinguisher, AFFF, Rating: 3A:20B, FERN No.: 5665.04-100	22/07/2013
YAF	YAF	Fire Extinguisher	9.0 L Foam type fire extinguisher, AFFF, Rating: 3A:20B, FERN No.: 5665.04-101	25/08/2015

**Comments:**

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

**End of the document**



**Certification Manager**