

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

| | | | |
|---------------------------|--|------------------------------|--|
| Company Name | Firex Distribution (Australia) Pty Ltd | Client ID | 105665 |
| Company Other Name | | Type of Certification | Product Certification; System 5 |
| Certification Standard | AS/NZS 1841.2-2007 : Portable fire extinguishers - Specific requirements for water type extinguishers | | |
| Scheme | Global-Mark Product Conformance Scheme | | |
| Certification Review Date | 25/06/2019 | Certification Expiry Date | 4/04/2024 |
| Certificate Issue Date | 25/06/2019 | Certificate Last Update Date | 29/07/2021 |

APPROVED COMPANY/SITE ADDRESS(ES):

Unit 5, 11 Packard Avenue Castle Hill NSW 2154 Australia

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: **A2ACCAD2F0047CD3CA2585C8002C357B**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:
In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

| Model Identification | Model Name | Brand Name | Product Description/Attributes | Date Approved |
|----------------------|------------|-------------------|--|---------------|
| FFA90AW_FX | FFA90AW_FX | FFA | 9.1 L Water type fire extinguisher, No additive, Rating: 3A, FERN No.: 5665.02-102 | 28/07/2021 |
| FXAW | FXAW | Firex | 9.1 L Water type fire extinguisher, No additive, Rating: 3A, FERN No.: 5665.02-100 | 22/07/2013 |
| YAW | YAW | Fire Extinguisher | 9.1 L Water type fire extinguisher, No additive, Rating: 3A, FERN No.: 5665.02-101 | 22/07/2013 |

Comments:

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

End of the document



Certification Manager