

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Firex Distribution (Australia) Pty Ltd	Client ID	105665
Company Other Name	Firex Trust	Type of Certification	Product Certification; System 1
Certification Standard	NEN 3374-1971 : Fire Fighting Equipment – Fire hose couplings and Ancillary Equipment		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	17/01/2020	Certification Expiry Date	20/12/2022
Certificate Issue Date	20/12/2019	Certificate Last Update Date	2/08/2020

APPROVED COMPANY/SITE ADDRESS(ES):

Unit 5, 11 Packard Avenue Castle Hill NSW 2154 Australia

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: 50967D2331788694CA2585B500132EE4

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
STFN 65F	Storz adaptor	Firex	Storz Adaptor – Female thread (BSP), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFN 65F	Storz adaptor	Firex	Storz Adaptor – Female thread, (NSW), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFSAF	Storz adaptor	Firex	Storz Adaptor – Female thread (SART), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFQLDF	Storz adaptor	Firex	Storz Adaptor – Female thread (QRT), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFCFAF	Storz adaptor	Firex	Storz Adaptor – Female thread (CFA), 63x8.47, Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFMFBF	Storz adaptor	Firex	Storz Adaptor – Female thread (MFB), 2 1/2" x 5 TPI (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	30/07/2020
STFN 65M	Storz adaptor	Firex	Storz Adaptor – Male thread (BSP), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFN 65M	Storz adaptor	Firex	Storz Adaptor – Male thread (NSW), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFSAM	Storz adaptor	Firex	Storz Adaptor – Male thread (SART), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFQLDM	Storz adaptor	Firex	Storz Adaptor – Male thread (QRT), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFCFAM	Storz adaptor	Firex	Storz Adaptor – Male thread (CFA), 63x8.47 (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	9/06/2020
STFMFBM	Storz adaptor	Firex	Storz Adaptor – Male thread (MFB), 2 1/2" (65mm), Working pressure: 16 Bar, Material: Forged AlMgSi Alloy	30/07/2020

Comments:

End of the document



Certification Manager

