

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	<b>Firex Distribution (Australia) Pty Ltd</b>	Client ID	<b>105665</b>
Company Other Name		Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS/NZS 1841.3-2007 : Portable fire extinguishers - Specific requirements for wet chemical type extinguishers</b>		
Scheme	<b>Global-Mark Product Conformance Scheme</b>		
Certification Review Date	<b>25/06/2019</b>	Certification Expiry Date	<b>8/04/2024</b>
Certificate Issue Date	<b>25/06/2019</b>	Certificate Last Update Date	<b>17/07/2020</b>


**APPROVED COMPANY/SITE ADDRESS(ES):**

**Unit 5, 11 Packard Avenue Castle Hill NSW 2154 Australia**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



Unique Certificate Code: **7B1CDF67214403AFCA2585A80025D1C1**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



[WWW.JAS-ANZ.ORG/REGISTER](http://WWW.JAS-ANZ.ORG/REGISTER)



**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**

*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FXWC20	FXWC20	Firex	2.0 L Wet chemical type fire extinguisher, Rating: 1A; 4F FERN No.: 5665.03-100	15/07/2009
FXWC70	FXWC70	Firex	7.0 L Wet chemical type fire extinguisher, Rating: 3A; 4F FERN No.: 5665.03-102	15/07/2009
YWC20	YWC20	Fire Extinguisher	2.0 L Wet chemical type fire extinguisher, Rating: 1A; 4F FERN No.: 5665.03-101	22/07/2013
YWC70	YWC70	Fire Extinguisher	7.0 L Wet chemical type fire extinguisher, Rating: 3A; 4F FERN No.: 5665.03-103	22/07/2013

**Comments:**

Extinguisher construction complies with AS/NZS 1841.1 standard requirements.

**End of the document**



**Certification Manager**